## COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF TAYLOR COUNTY RURAL ELECTRIC	)
COOPERATIVE CORPORATION FOR CERTIFICATE OF	) CASE NO.
PUBLIC CONVENIENCE AND NECESSITY	ý 98-119

## ORDER

IT IS ORDERED that Taylor County Rural Electric Cooperative Corporation ("Taylor County") shall file the original and eight copies of the following information with the Commission with a copy to all parties of record within 25 days from the date of this Order. Taylor County shall furnish the name of the witness who will respond at the public hearing, if one is held, to questions concerning each item of information.

- 1. The Commission's Order in Case No. 95-125,¹ dated September 15, 1995 stated, "Taylor County shall install minimum/maximum voltmeters so actual voltmeter readings will be available for comparison to the calculated voltages in its next work plan."
  - a. Has Taylor County installed any minimum/maximum voltmeters?
- (1) If yes, provide the voltage readings and show the substation, line section, and date when each reading was taken. If the actual reading differs from the calculated voltage by more than three volts, explain the reason for the difference.
- (2) If no, explain why Taylor County did not comply with the Commission Order. Also explain how Taylor County determined that the voltage drop

Case No. 95-125, The Application of Taylor County Rural Electric Cooperative Corporation for Certificate of Public Convenience and Necessity.

studies filed in this case are accurate and should be used as basis for the improvements recommended in this Work Plan.

- 2. Refer to Page 74 entitled, "Summary of Economic Comparisons from Power Supply Study and Power Supply Letter of Concurrence." Explain how the present worth numbers listed under column "EKPC" and "TCRECC," for PLAN A1, PLAN A2, and PLAN B1 were derived. Provide all supporting calculations.
- 3. When does Taylor County anticipate filing with the Commission a case seeking approval of financing the Work Plan proposed in this case?

Done at Frankfort, Kentucky, this 30th day of April, 1998.

PUBLIC SERVICE COMMISSION

For the Commission

ATTEST:

Executive/Director